FORM 'D'

(Form of licence under sub - section (1) of section 6 of the Tamil Nadu Public Building (licensing) Act 1965 the Tamil Nadu) Act 13 1965 referred to in rule 6 of the Tamil Nadu Public Bulidings (Licensing) Rules 1966.

LICENCE

Licence No. 20/2020

Fee Rs. 5000/-
Remitted in Ch. No. 2, Dated: 04.06.2020.
Bank of Baroda, Perundurai.

Taluk Office,
Perundurai.
Dated : .06.2020

Ref. No. K.Dis. 2379/2020/A3

Licence is here by granted to *THE CORRESPONDENT, M/s. MAHARISHI VIDYA MANDIR CBSE SCHOOL,* resident at ***Chennimalai – Perundurai Road, Ingur Village,*** Perundurai Taluk, Erode District, for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned here under:-

1. The period of validity of the Licence shall be Renewed from **01.06.2020 To 31.05.2023** (Inclusive of Both Days)

TAHSILDAR
PERUNDURAI

STATEMENT TO ACCOMPANY THE LICENCE

Location of the building Door No. Street No. and Name of the Place	Purpose for which the building is licensed to be used as a public building	No. of Persons to be accommodated.
S.F. No. 828/1C1 Chennimalai – Perundurai Road, Ingur Village & Panchayat, Perundurai Taluk, Erode District.	**RUNNING A SCHOOL**	*1200 Persons (One Thousand and Two Hundred only)*

Dated : .06.2020

TAHSILDAR
PERUNDURAI.

PRINCIPAL
RISHI VIDYA MANDIR
R SECONDARY SCHOOL
ur, Perundurai (Tk),
Dt) - 638 052. Tamilnadu

CORRESPONDENT
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu.

FORM - A

(Form of application under sub-section (1)/sub-section (2) of section 4 of the Madras Public Buildings (Licensing) Act, 1965 (Madras Act 13 of 1965) referred to in rule 3 of the Madras Public Buildings (Licensing) Rules, 1965).

From

The Correspondent
MAHARISHI VIDYA MANDIR CBSE SCHOOL,
R.S.F.No.828/1, New Sub Division No.828/1C,
Road join to Chennimalai - Perundurai Road,
Ingur , Ingur village Panchayath,
Perundurai Taluk, Erode District.

To

THE TAHSILDAR,
PERUNDURAI.

Sir,

I intend/to use the building/to continue to use the existing Public building/to use the existing building not at present used as a Public / which is situated in the site or plot of land. Town or Revenue Survey No. R.S.F.No.828/1, New Sub Division No.828/1C1, Street or Road, Road join to Chennimalai - Perundurai Road, Ingur , Ingur village Panchayath, Perundurai Taluk the ward or division/village/ Taluk/ district Erode District and specified in the statement enclosed, as a public building for a period of Three years and month from the **01.06.2020 To 31.05.2023.**

2. The year of construction and the present approximate cost of construction and the purpose for which is to be used or is being used as a public building are also furnished in the statement accompanying this application.

3. I enclose a Chelan for Rs.5000.00 (Rupees Five Thousand Only)

4. I also enclose a certificate of structural soundness in the prescribed from by Engineer **Sri. P. RANGASWAMI**, B.E., Panel Engineer Class-IA, No.117506/89/C2, Dt.15.11.1989.

Dated: 21.05.2020

Signature of the owner of the building

CORRESPONDENT
Maharishi Vidya Mandir
Ingur, Erode - 52.

Enclosures: (1) Statement

(2) Chelan for Rs._____ towards the application fee.

"Explanation: Separate application shall be made in respect of each building".

PRINCIPAL
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu

CORRESPONDENT
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu.

STATEMENT ACCOMPANYING FORM A

1	Door number of building	:	R.S.F.No.828/1, New Sub Division No.828/1C1,
2	Location (Street Number, ward number, name of place, i.e. Corporation /Municipality/ Panchayath / Panchayath Union/Township/ Cantonments)	:	Road join to Chennimalai - Perundurai Road, Ingur, Ingur village Panchayath, Perundurai Taluk, Erode District.
3	Year of Construction	:	2014.
4	Approximate cost of construction as per current rates		Rs.2,65,00,000.00
5	Purpose for which the building is being used of proposed to be used.	:	***"MAHARISHI VIDYA MANDIR CBSE SCHOOL"***(Class rooms, Office, Lab, Library, Staff room, Toilet etc.,)
6	Purpose for which the building has hither to been used	:	***"MAHARISHI VIDYA MANDIR CBSE SCHOOL"***(Class rooms, Office, Lab, Library, Staff room & Toilet etc.,)
7	Details of Construction of the building (Particulars of the foundation soil), specifications of the various parts under:-		
	(1) Foundation	:	Plain cement concrete, R.C.C. column footing,.
	(2) Basement	:	All round R.C.C. Belt beam connected with RCC Column
	(3) Superstructure	:	RCC Filler walls with Brick masonry in cement mortar.
	(4) Floor and roof (are to be given)	:	P.C.C. flooring Top laid with Granite, Roofing is RCC Concrete Slab
8	Period for which license is required	:	**3 Years (01.06.2020 To 31.05.2023)**.
9	Number of persons to be accommodated	:	1200 Nos

Dated:21.05.2020

Signature of the Engineer
Er. P. RANGASWAMI, B.E.,
Chief Engineer P.W.D. (Retd),
Regd. Valuer for Income Tax,
Approved Valuer For T.U.C.
Panel Engineer Public Buildings
Class - 1A, No : 11/005 / P9 / C2 /
EVEREST ENGINEERS
363, Nainaji Road,
ERODE - 638001. Cell : 98432 85656

Signature of the owner of the building

CORRESPONDENT
Maharishi Vidya Mandir
Ingur, Erode - 52.

DECLARATION

I **P.RANGASWAMI** son of **PERUMAL GOUNDER** residing at 363,Nethaji Road, Erode – 638 001 do hereby declare that I possess the qualification and experience specified in the Table to rule II of the Public Building (Licensing) Rules 1966, for issuing the certificate of structural soundness of the building covered by the certificate.

Station: ERODE,
Date : 21.05.2020

Signature of the certifying Engineer
Er. P. RANGASWAMI, B.E.,
Chief Engineer P.W.D. (Retd),
Regd. Valuer for Income Tax,
Approved Valuer For T.I.I.C.
Panel Engineer Public Buildings
Class - 1A, No : 117506 / 89 / C2 /
EVEREST ENGINEERS
363, Nethaji Road,
ERODE - 638001. Cell : 98432 65656

(i) Name and address (in block letters)

Er. P. RANGASWAMI, B.E.,
EVEREST ENGINEERS,
363,Nethaji Road,
Erode – 638 001.
Mobile : ***98432 65656.***

(ii) Engineering Qualification :

B.E., Degree in Madras University.

(iii) Number of years of experience and nature there of More than 50 Years in **P.W.D.** and private practicing etc.,

Date: 21.05.2020

Signature of the Engineer
Er. P. RANGASWAMI, B.E.,
Chief Engineer P.W.D. (Retd),
Regd. Valuer for Income Tax,
Approved Valuer For T.I.I.C.
Panel Engineer Public Buildings
Class - 1A, No : 117506 / 89 / C2 /
EVEREST ENGINEERS
363, Nethaji Road,
ERODE - 638001. Cell : 98432 65656

FORM – C

(Form of certificate of structural soundness under sub. section (4) of the Tamilnadu Public Buildings (Licensing) Act (Tamilnadu Act 13 of 1965 referred to in Rule of the Tamilnadu Public Building Licensing) Rules 1965.

I certify that I have inspected the ***MAHARISHI VIDYA MANDIR CBSE SCHOOL "*** building mentioned in the statement and furnish below its salient technical features.

1.	Foundation		
	i)	Depth below ground level	: 1.83 M -
	ii)	Nature of soil met with at foundation level	: Hard gravel
	iii)	Pressure of foundation	: 32.00 Tones/Sqm.
	iv)	Probable safe bearing capacity of the soil met with at foundation	: 45.00 Tones/Sqm.
2	Superstructure		
	i)	Maximum stress in the most critical section of masonry and concrete.	: Brick work in cm- 24.82 Tones/Sqm. R.C.C. Column 23.90 Kg/Sq.cm.
	ii)	Nature of masonry any concrete and its safe permissible stress	: Brick work in cm - 55.00 Tones/Sqm. RCC Column 42.00 Kg/Sq.cm.

The Structural soundness of the building has been verified by me with reference to ISI loading standards 874 (latest version) and other relevant Indian Standard code of Practice and I declare that the building for the purpose noted in the Statement. A license may be granted for the period from. **01.06.2020 To 31.05.2023.** (inclusive) two dates.

Date: 21.05.2020

Signature of the Engineer

Er. P. RANGASWAMI, B.E.,
Chief Engineer P.W.D. (Retd),
Regd. Valuer for Income Tax,
Approved Valuer For T.N.L.C.
Panel Engineer Public Buildings
Class - 1A, No : 117506 / 89 / C2 /
EVEREST ENGINEERS
363, Nethaji Road,
ERODE - 638001. Cell : 98432 65656

STATEMENT TO ACCOMPANY THE CERTIFICATE STRUCTURAL SOUNDNESS

Location of the building Door No. Street and name of the place	Age of the building	Number of stories	Short description of structures steel / RCC framed load bearing masonry	Purpose for which the building is certified for use	The period for which the building will be structurally sound	No. of persons to be accommodated
R.S.F.NO.828/1, Sub Division No.828/1C1, Road join to Chennimalai - Perundurai Road, Ingur , Ingur Village Panchayath, Perundurai Taluk, Erode District	3 Years	Ground + Two	(RCC Framed structure)Foundation & Basement - Plain cement concrete & RCC Belt Beam Connected with Coloum, Super structure- RCC Filler walls with Brick in CM, Roofing -RCC Concrete Slab, Flooring – Plain cement concrete Top Laid with Granite.	"*MAHARISHI VIDYA MANDIR CBSE SCHOOL*" .(Class rooms, Office, Lab, Library, Staff room ,Toilet etc.),	3 Years only **(01.06.2020 To 31.05.2023).**	1200 Nos.

ADDITIONAL CERTIFICATE

I certify that all the buildings and structures including compound wall have been covered by Stability Certificate. There is no structure in the building used or unused which is not unsafe for the children.

Date:21.05.2020

Signature of the Engineer
Er. P. RANGASWAMI, B.E.,
Chief Engineer P.W.D. (Retd),
Regd. Valuer for Income Tax,
Approved Valuer For T.U.C.
Panel Engineer Public Buildings
Class - 1A, No: 11750 / 89 / C2 /
EVEREST ENGINEERS
35, Nehru Road,
ERODE - 638001. Cell : 99432 65656

PRINCIPAL
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu

CORRESPONDENT
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu.

FIRE SAFETY CERTIFICATE

R.C.No:586/2019 **Dated:22.11.2019**

Certified that the **Maharishi Vidya Mandir, New Sub Division No :828/1C1 (Old SF.No:142), Ingur via, Perundurai(Tk),Erode(Dt) - 638052.** Comprised of **NIL** basement(s) and **G+2**(Upper Floors) owned /occupied by **Maharishi Vidya Mandir** have complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rules, and verified by the Officers concerned of Fire Service on **22.11.2019** by **Mr.S.Velusamy** in the presence of **Mr.S.R.Praveen – Correspondent** and that the building / Premises is fit for occupancy class **PREKG – XII** with effect from **22.11.2019** for period of 1 year in accordance with rule and subject to compliance of the conditions.

Issued on **22.11.2019** at **Perundurai Fire & Rescue Station** by

FIRE AND RESCUE STATION PERUNDURAI

STATION OFFICER
FIRE AND RESCUE STATION
PERUNDURAI - 638 052.

Signature with Seal : _____

Name : Thiru.S.Velusamy

Designation : Station Officer

To

Mr.S.R.Praveen - Correspondent,
Maharishi Vidya Mandir,
Ingur,
Perundurai (Tk),
Erode(Dt) - 638052

PRINCIPAL
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu

CORRESPONDENT
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu.

Government of Tamil Nadu

Department of Public Health & Preventive Medicine

SANITARY CERTIFICATE

APPENDIX-3 (CHAPTER III RULE, 24)

I hereby declare that I have inspected the School **MAHARISHI VIDYA MANDIR, CHENNIMALAI – PERUNDURAI ROAD, INGUR 638 052, PERUNDURAI TALUK, ERODE DISTRICT.** building and premises on the day of **04.12.2019** and certify.

a) The class room and surroundings are maintained neat and clean.
b) The sanitary arrangements provided are adequate and satisfactory.
c) The Drinking water arrangements provided is satisfactory.

This Certificate is issued under subject to the following conditions:

1. The garbage generated within the school premises should be collected and disposed off properly by appointing required sanitary staff.
2. On any account, the Garbage should not be burnt.
3. The children should be educated to prevent the usage of plastics in the school/institution premises and no one should bring plastic carry bags, use and throw tumblers to the school/institution.
4. Fire precaution measures, and First Aid Box, should be provided.
5. Child Labor should not be engaged on any account.
6. Every person in charge of place of public work should use small display and exhibition board at conspicuous place stating that the place is a "No smoking Area Smoking here is an offence" and "Tobacco-free Institution. Sale or offer cigarettes or other tobacco products are strictly prohibited within the radius of 100 yards from this institution". which shall be both in Tamil and English and the version in the second place below the Tamil version.
7. This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of sanitation, improper maintenance of the building as well as toilets in the institute.
8. This Sanitary Certificate valid **one year** only from the date issue.

R. No. 4396 /A5/2019/Dated: 05 .12.2019

PRINCIPAL
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu

04/12/19
Block Health Supervisor,
Primary Health Centre,
Chennimalai.

Counter Signed.

Deputy Director of Health Services,
Erode.

To
THE CORRESPONDENT,
MAHARISHI VIDYA MANDIR,
CHENNIMALAI - PERUNDURAI ROAD,
INGUR 638 052,
PERUNDURAI (TK), ERODE DISTRICT.

CORRESPONDENT
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu.

AWE CARE®
PRIVATE LIMITED
Analytical & Research Laboratories

ISO 9001 NABCB QMO11
An ISO 9001 : 2015 Certified Lab

03.04.2021

CERTIFICATE OF ANALYSIS

Company/Client Name : M/s Maharishi Vidya Mandir Senior Secondary School,
Address : Ingur, Perundurai, Erode
Reference letter No. and Date : Nil/31.03.21
Commenced On : 31.03.21
Report No. : BX3102
Detail of Sample :

Sample Received on	Quantity of Sample	Sample ID	Type of Sample	Sample Given by
31.03.21	1000 ml	Drinking Water	Water	Client.

Results-Analysed on Received Basis:-

S.No	Parameters	Results	IS Drinking Water Characteristics IS 10500: 2012	Procedure
1	MPN of Coliform Bacteria for 100ml	3.00	<10 nos. in 100ml	IS 3025
2	*E.coli* P/A	Absent	Absent	IS 3025

- End of the report -

3/4/21

AWE CARE LAB ISO Certified Lab ERODE

Dr. E.S.Karthy M.Sc., Ph.D.
Chief Analyst

PRINCIPAL
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu

CORRESPONDENT
MAHARISHI VIDYA MANDIR
SENIOR SECONDARY SCHOOL
Ingur, Perundurai (Tk),
Erode (Dt) - 638 052. Tamilnadu.